12 BZ-BL-P1



BZ - SERIES

SINGLE VANE - SEWAGE & WASTE WATER PUMPS

SPECIFICATIONS

■ FEATURES

- Single Vane, Cast Iron, impeller passes 3" diameter solids without clogging providing for highly efficient pumping of raw sewage and waste water.
- Double inside mechanical seals with silicon carbide faces, running in an oil filled chamber and further protected by a lip seal, provides for the most durable seal design available.
- Highly efficient, continuous duty, air filled, copper wound motor with class F, insulation minimizes the cost of operation.
- Built in thermal & amperage sensing, protector prevents motor failure due to overloading, single phasing (in three phase units), or accidental run -dry conditions.

5. Double shielded, permanently lubricated, high temperature C3 ball bearings rated for a B-10 life of 60,000 hours, extend operational life.

APPLICATIONS

- Residential, commercial, industrial sewage, effluent, wastewater and site drainage.
- 2. Decorative waterfalls, fountains and fish ponds.
- 3. Raw water supply from rivers or lakes.





■ SPECIFICATIONS

Discharge Size
Horsepower Range
Performance Range Capacity
Head

Maximum water temperature Materials of Construction

Casing Impeller Shaft Motor Frame Fasteners

Mechanical Seal Elastomers

Impeller Type Solids Handling Capability

Bearings

Motor Nomenclature Type, Speed, Hz. Voltage, Phase

Insulation

Accessories
Operational Mode

■ STANDARD

4" Npt (100 mm) 2 ~15 Hp. (1.5 ~ 11 kW) 105.7 ~ 951.0 Gpm. (.40 ~ 3.60 m³/min) 21.0 Ft. ~ 101.7Ft. (6.4 ~ 31.0 m) 104° F. (40° C.)

ASTM 48 Class 35 Cast Iron ASTM 48 Class 35 Cast Iron 420,403 Stainless Steel ASTM 48 Class 35 Cast Iron 304 Stainless Steel

Silicon Carbide NBR (Nitril Buna Rubber)

Enclosed Single Vane, solids handling. 3.15" (80 mm)

Pre-lubricated, Double Shielded

Air Filled, 1800 Rpm, 60 Hz. 208-230, 230 or 440, 460 or 575 V. (3 Phase)

Class F Submersible Power Cable 32' (10 m) Manual

OPTIONS

Nema 3R inverter available for 230 V.,1 Ph. operation from 2~5 Hp.

Length as Required

Model TOS Slide rail system




BZ - SERIES (12" base pump)

SEWAGE & WASTEWATER PUMPS

PERFORMANCE RANGE

GROUP PERFORMANCE RANGE



CAPACITY

<u>No</u>	te				

Ex.



MODEL (TO)350BZ637H -61

PUMP TYPE

PHASE

BZ - SERIES SEWAGE & WASTEWATER PUMPS

PERFORMANCE CURVE

INS. CLASS

BORE	HP	kW	RPM	SOLIDS DIA.	LIQUID	SG.	VISCOSITY	TEMP.
14"/350mm	50	37	SS 1200	3.54"/90mm	Water	1.0	1.123cSt.	60°F


STARTING METHOD

HZ

Sewage & Wastewater Pump 460 / 575 60 3 Star-Delta -/-INS. CLASS CURVE No. DATE PHASE **VOLTAGE AMPERAGE** HZ STARTING METHOD

AMPERAGE


VOLTAGE






BZ-SERIES SEWAGE & WASTEWATER PUMPS

DIMENSIONS



350BZ622H -61 350BZ630H -61 350BZ637H -61



C.W.L. :Continuous running Water Level L.W.L. :Lowest running Water Level

DIM ENSIONS: USCS (Inch)

DIMILIANIONS.03	,,,,,	•,												
Model	HP	NOM.		Pump & Motor									L.W.L.	*Wt.
		SIZE	Α	A1	A2	А3	В	D	D1	D2	Н	W1	W2	(lbs.)
350BZ622H-61	30	14"	59 3/8	34	15 3/4	17 11/16	34 13/16	31 1/2	15 3/4	15 3/4	66	57 7/8	263/8	2010
350BZ630H-61	40	14"	59 3/8	34	15 3/4	17 11/16	34 13/16	31 1/2	15 3/4	15 3/4	66	57 7/8	263/8	2090
350BZ637H-61	50	14"	59 3/8	34	15 3/4	17 11/16	34 13/16	31 1/2	15 3/4	15 3/4	66	57 7/8	263/8	2070

DIMENSIONS:MI	DIMENSIONS:METRIC (mm)													*Excluding Cable			
Model	kW	NOM.		Pump & Motor									L.W.L.	*Wt.			
		SIZE	Α	A1	A2	А3	В	D	D1	D2	Н	W1	W2	(kg)			
350BZ622H-61	22	350	1508	863	400	450	885	800	400	400	1677	1470	670	910			
350BZ630H-61	30	350	1508	863	400	450	885	800	400	400	1677	1470	670	950			
350BZ637H-61	37	350	1508	863	400	450	885	800	400	400	1677	1470	670	940			




BZ-SERIES SEWAGE & WASTEWATER PUMPS


DIMENSIONS


TO350BZ622H -61 TO350BZ630H -61 TO350BZ637H -61

Guide rail Model: TO-350

Weight: 640 lbs. (290kg)







DIMENSIONS: USCS (Inch)

Model	HP	NOM.					Pump 8	Motor					C.W.L.	L.W.L.	*Wt.
		SIZE	Α	A1	A2	А3	D	D1	D2	Н	H1	H2	W1	W2	(lbs.)
TO350BZ622H -61	30	14"	46 1/4	33 7/16	12 3/4	27 9/16	25 7/8	11 5/16	149/16	62 13/16	83 3/16	8 7/16	54 1/2	23 1/4	1790
TO350BZ630H -61	40	14"	46 1/4	33 7/16	12 3/4	279/16	25 7/8	11 5/16	149/16	62 13/16	83 3/16	8 7/16	54 1/2	23 1/4	1870
TO350BZ637H -61	50	14"	46 1/4	33 7/16	12 3/4	279/16	25 7/8	11 5/16	149/16	62 13/16	83 3/16	8 7/16	54 1/2	23 1/4	1850


DIMENSIONS:METRIC	C (mm)												*Exclud	ding TOS 8	& Cable
Model	kW	NOM.		Pump & Motor										L.W.L.	*Wt.
		SIZE	Α	A1	A2	А3	D	D1	D2	Н	H1	H2	W1	W2	(kg)
TO350BZ622H -61	22	350	1174	850	324	700	658	288	370	1595	2113	215	1385	590	810
TO350BZ630H -61	30	350	1174	850	324	700	658	288	370	1595	2113	215	1385	590	850
TO350BZ637H -61	37	350	1174	850	324	700	658	288	370	1595	2113	215	1385	590	840



BZ-SERIESSEWAGE & WASTEWATER PUMPS

SECTIONAL VIEW

350BZ622H -61 350BZ630H -61 350BZ637H -61



PART#	DESCRIPTION	MAIN MATERIAL / NOTE	RELATED ASTM, AISI CODE	RELATED EN CODE	QTY
	Power Cable	Chloroprene Sheath AWG 6/4 - 32ft			1
1	PowerCable	Chloroprene Sheath AWG 6/3 - 32ft			1
	Control Cable	PVC Sheath AWG 16/3 - 32ft			1
3	Gland	Cast Iron	A48M Class30B	EN 1561 GJL-200	2
6	Staffing Box	Cast Iron	A48M Class30B	EN 1561 GJL-200	2
20	Pump Casing	Cast Iron	A48M Class35B	EN 1561 GJL-250	1
21	Impeller	Cast Iron	A48M Class35B	EN 1561 GJL-250	1
22	Suction Cover	Cast Iron	A48M Class35B	EN 1561 GJL-250	1
23	Strainer Stand	Cast Iron	A48M Class30B	EN 1561 GJL-200	1
25	Mechanical Seal	Silicon Carbide / H-60			1
26	Oil Seal	NBR / TC11014014			1
29	Oil Casing	Cast Iron	A48M Class30B	EN 1561 GJL-200	1
30	Oil Lifter	Steel (Cold Rolled)	A109/A1008	EN 10130	1
35A	Oil Plug	Stainless Steel	S 30400	1.4301	2
35B	Oil Plug	Stainless Steel	S 30400	1.4301	2
36	Lubricant	Turbine Oil ISO VG32 or SAE10W-20			
37	Discharge Bend	Cast Iron	A48M Class30B	EN 1561 GJL-200	1
46	Air Valve	Nylon			1
48	Welded Flange	Steel / 14"	A283 Grade D	EN 10025 S275	1
50	Motor Bracket	Cast Iron	A48M Class30B	EN 1561 GJL-200	1
52A	Upper Bearing	#6310ZZC3			1
52B	Lower Bearing	#6315ZZC3			2
53	Motor Protector				3
54	Shaft	Stainless Steel	S 42000	1.4028	1
55	Rotor				1
56	Stator				1
60	Bearing Housing	Cast Iron	A48M Class30B	EN 1561 GJL-200	1
64	Motor Housing	Cast Iron	A48M Class30B	EN 1561 GJL-200	1
71	Shaft Sleeve	Stainless Steel	S 30400	1.4301	1
72	Lifting Lug Bolt	Steel	A283 Grade D	EN 10025 S275	2
90	Leakage Sensor (Electrode)	Stainless Steel			1

Jan. 17 60-SS-BZ-01



BZ - SERIESSEWAGE & WASTEWATER PUMPS

SAMPLE SPECIFICATIONS

1_	SC	n:	PF	OF	SU	PP	Y	_

Furnish and install TSURUMI Model	Submersib	le Pump(s).	Each unit shall be capable of
deliveringGPM (m³/min) at	_Feet (m) TDH.	The pump(s) shall be designed
to pump waste water, sewage or effluent containing	inch (mm) diam	eter solids without damage
during operation. The pump(s) shall be designed so th	at the shaft po	wer required	d (BHP)/(kW) shall not exceed
The motor rated output throughout the entire operating	range of the p	oump perforn	nance curve. The pump
discharge size shall beinch, (mm).			

2. MATERIALS OF CONSTRUCTION -

Construction of major parts of the pumping unit(s) including pump casing, impeller, and discharge elbow shall be manufactured from gray cast iron, ASTM A48 CLASS 30B. Unit(s) shall have a field adjustable and or replaceable, cast iron wear plate or wear rings. Internal and external surfaces coming into contact with the pumpage shall be protected by a fused polymer coating. All exposed fasteners shall be stainless steel. All units shall be furnished with a discharge elbow with 150 lb. (10 kg/cm²) flat face flange and NPT companion flange. Impellers shall be of the single vane, enclosed, solids handling design equipped with back pump out vanes and shall be slip fit to the shaft and key driven. The pump casing shall incorporate an air relief valve.

3. MECHANICAL SEAL -

All units shall be furnished with a dual inside mechanical shaft seal located completely out of the pumpage, running in a separate oil filled chamber and further protected by an exclusionary oil seal located between the bottom seal faces and the fluid being pumped. The oil chamber shall be fitted with a device that shall provide positive lubrication of top mechanical seal, (down to one third of the standard oil level). The device shall not consume any additional electrical power. Mechanical seals shall rated to preclude the incursion of water up to 42.6 PSI. (98.4 Ft.). Units shall have silicon carbide mechanical seal faces. Mechanical seal hardware shall be stainless steel.

4. MOTOR -

The pump motor(s) shall be _____Hp., _____kW., _____V., 60 Hz., 3 Phase and shall be NEMA MG-1, Design Type B equivalent. Motor(s) shall be rated at _____ full load amps. Motor(s) shall have a 1.15 service factor and shall be rated for 20 starts per hour. Motor(s) shall be air filled, copper wound, class E or F(7.5 Hp. and above) insulated with built in thermal protection for each winding. Motor shaft shall be 420 or 403 stainless steel and shall be supported by two permanently lubricated, high temperature ball bearings, with a B-10 life rating at best efficiency point of 60,000 hours. On units up to 10 Hp. (7.5 kW), the bottom bearing shall be single row, double shielded, C3, deep groove type ball bearings. On units 15 Hp. (11 kW), the bottom bearing shall be two row, double shielded, C3, deep groove type ball bearings. The top bearing on all units shall be single row, double shielded, C3, deep groove type ball bearings. Motor housing and bearing housing shall be gray cast iron, ASTM A48 CLASS 25B or 30B (7.5 Hp. and above). Motors shall be D.O.L. or Star-delta start (15 Hp.), and shall be suitable for across the line start or variable speed applications, utilizing a properly sized variable frequency drive.

5. POWER CABLE AND CABLE ENTRANCE -

The pump power cable shall be suitable for submersible pump applications. Units up to 5 Hp. shall be supplied with a cable entrance that incorporates built in strain relief, a one piece, three way mechanical compression seal with a fatigue reducing cable boot. On units 7.5 Hp. and above, the cable entrance shall incorporate built in strain relief, and combination three way mechanical compression sealing with a fatigue reducing/thermal expansion rubber boot. The power cable shall be field replaceable utilizing standard submersible pump cable. The cable entrance assembly on all units shall contain an anti-wicking block to eliminate water incursion into the motor due To capillary wicking should the power cable be accidentally damaged.