Apr. 12



LHW- SERIES HIGH HEAD DEWATERING PUMP

SPECIFICATIONS

■ FEATURES

- Enclosed, high chrome iron, impellers, with replaceable / adjustable high chrome iron wear rings increases wear resistance when pumpage contains abrasive particles.
- 2. Double inside mechanical seals with silicon carbide faces, (both top and bottom) running in an oil filled chamber and further protected by a lip seal running against a replaceable, 430 stainless steel shaft sleeve, provides for the most durable seal design available.
- 3. Highly efficient, continuous duty air filled, copper wound motor with class B, F insulation minimizes the cost of operation.
- 4. Built in thermal & amperage Sensing protector prevents motor failure due to-

- overloading or accidental run -dry conditions.
- 5. Double shielded, permanently lubricated, high temperature C3 ball bearings rated for a B-10 life of 60,000 hours, extend operational life.
- Top discharge, flow-thru design enables operation at low water levels for extended Periods.

■ APPLICATIONS

- Residential, commercial, industrial wastewater and construction site drainage.
- 2. Effluent transfer.
- 3. Decorative waterfalls and fountains.
- Raw water supply from rivers or lakes...







■ SPECIFICATIONS

Discharge Size Horsepower Range Performance Range Capacity Head

Maximum water temperature Materials of Construction

Casing Impeller Shaft Motor Frame Fasteners

Seal Pressure Relief Ports Mechanical Seal

Elastomers Impeller Type

Solids Handling Capability

Bearings

Motor Nomenclature Type, Speed, Hz. Voltage, Phase Insulation

Accessories

Operational Mode

■ STANDARD

2" ~ 4" NPT (50 ~ 100 mm) 4 ~ 40 HP. (3.0 ~ 30 kW) 26.4 ~ 322.0 GPM. (0.10 ~ 1.22 m³/min) 54.1 Ft. ~ 417.0 Ft. (16.5. ~ 127.1 m) 104° F. (40° C.)

Cast Iron , Ductile Cast Iron High Chrome Cast Iron 420 Stainless Steel Cast Iron 304 Stainless Steel 7.5 - 40HP (5.5 - 30kW) Silicon Carbide NBR (Nitrile Butadiene Rubber) Enclosed, two stage, solids handling. 0.236 - 0.334" (6.0 - 8.5mm)

Prelubricated, Double Shielded

Air Filled, 3600 RPM, 60 Hz. 208/230/460/575 V., 3 Phase Class B, F

Submersible Power Cable 65' (20 m)

Manual

OPTIONS


Length as Required

TS-301 Float Switch

LH-W SERIES HIGH HEAD - DEWATERING PUMPS

PERFORMANCE RANGE

GROUP PERFORMANCE RANGE




Jun. 11 60-PC-LHW-05

TSURUMI PUMP

LH-W SERIES HIGH HEAD - DEWATERING PUMPS

PERFORMANCE CURVE

MODEL		BORE	HP	KW	RPM	SOLIDS DI	Α	LIQUID	SG.	VISC	OSITY	TEMP.
LH430W-61		4"/100mm	40	30	3475	0.334"/8.5m	ım	Water	1.0	1.12	23 cSt	60°F
PUMP TYPE		PHASE	VOL	TAGE	GE AMPERAGE H		HZ	STARTING METHOD		DD	INS. C	LASS
High Head Dewatering Pump		3	460	/ 575	48	.0 / 38.5	60	Star-De	lta		ı	=
CURVE No.	DATE	PHASE	VOL	TAGE	AM	PERAGE	HZ	STARTING N	IETHO	D	INS. C	LASS
-	-	-		-		-	-	-				-




v. 09



LH-W SERIES HIGH HEAD - DEWATERING PUMPS


DIMENSIONS

LH322W-61 LH430W-61



3" or 4" JIS20K (300PSI) Flange with

3" or 4" NPT Companion Flange



C.W.L.: Continuous running Water Level

DIMENSIONS: USCS (Inch)

Model	HP	NOM.	Pι	ımp & Mot	C.W.L.	Wt.	
		SIZE	В	B1	D	W1	(lbs.)
LH322W-61	30	3"	48 5/8	38 1/2	13	11 3/4	670
LH430W-61	40	4"	54 1/8	40 1/16	14 3/8	11 3/4	714

DIMENSIONS: METRIC (mm)

Model	HP	NOM.	Pι	ımp & Mo	C.W.L.	Wt.	
		SIZE	B B1 D		D	W1	(lbs.)
LH322W-61	22	80	1235	978	330	300	304
LH430W-61	30	100	1375	1018	365	300	324


7. 09 SEC-LHW-05



LH-W SERIES HIGH HEAD - DEWATERING PUMPS

SECTIONAL VIEW

LH430W-61



ITEM#	DESCRIPTION	MAIN MATERIAL / NOTE	ASTM, AISI CODE	RELATED EN CODE	Q'TY
1	Power Cable	Chloroprene Sheath AWG 4/6, 6/1, 14/2 -65ft			1
3	Gland	Cast Iron	A48M Class30B	EN 1561 GJL-200	1
6	Stuffing Box	Cast Iron	A48M Class30B	EN 1561 GJL-200	1
20A	Upper Pump Casing	Cast Iron	A48M Class30B	EN 1561 GJL-200	1
20B	Middle Pump Casing	Cast Iron	A48M Class30B	EN 1561 GJL-200	1
20C	Lower Pump Casing	Cast Iron	A48M Class30B	EN 1561 GJL-200	1
21	Impeller	High Chrome Cast Iron	A532 Class TypeA	DIN 1695 G-X260Cr27	2
23	Suction Strainer	Steel	A283 Grade D	EN 10025 S275	1
25	Mechanical Seal	Silicon Carbide / HT-4550N			1
26	Labyrinth Ring	Stainless Steel	S 30400	1.4301	2
29	Oil Casing	Cast Iron	A48M Class30B	EN 1561 GJL-200	1
30	Oil Lifter	PBT Resin W/GF40			1
34	Mouth Ring	High Chrome Cast Iron	A532 Class TypeA	DIN 1695 G-X260Cr27	2
35	Oil Plug	Stainless Steel	S 30400	1.4301	3
36	Lubricant	Turbine Oil ISO VG32 or SAE 10W-20			
37	Discharge Pipe	Steel Pipe (& Steel) / 4" JIS20K	A53 Type F (& A283 Grade D)	DIN 1615 St 33 (& EN 10025 S275)	1
43	Cathodic Protection Plate	Aluminium Alloy			2
48	Companion Flange	Cast Iron / NPT 4" JIS20K	A48M Class30B	EN 1561 GJL-200	1
50	Motor Bracket	Cast Iron	A48M Class30B	EN 1561 GJL-200	1
51	Head Cover	Cast Iron	A48M Class30B	EN 1561 GJL-200	1
52A	Upper Bearing	#6307ZZC3			1
52B	Lower Bearing	#7311DBC3			1
53	Motor Protector				3
54	Shaft	Stainless Steel	S 42000	1.4028	1
55	Rotor				1
56	Stator				1
60	Bearing Housing	Cast Iron	A48M Class30B	EN 1561 GJL-200	1
64	Motor Housing	Cast Iron	A48M Class30B	EN 1561 GJL-200	1
65	Outer Cover	Steel	A283 Grade D	EN 10025 S275	1
71A	Shaft Sleeve (Upper)	Stainless Steel	S 40300	1.4000	1
71B	Shaft Sleeve (Lower)	Stainless Steel	S 40300	1.4000	1
72	Lifting Lug Bolt	Stainless Steel	S 30400	1.4301	2

Sep. 01 60-SS-LHW-01



LH-W SERIES HIGH HEAD - DEWATERING PUMPS

SAMPLE SPECIFICATIONS

_		 	 		
•	SCO			_ \	~
			 ,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	_	T -

Furnish and install TSURUMI Model	Submersible	Pump(s).		
Each unit shall be capable of delivering	GPM (_m³/min) at	Feet(m) TDH.
The pump(s) shall be designed to pump waste w				
shall be designed so that the shaft power				
throughout the entire operating range of the	pump performance	curve. Pump(s)	shall be of the	top discharge
flow through design.				

2. MATERIALS OF CONSTRUCTION -

Construction of major parts of the pumping unit(s) shall be gray cast iron, ASTM A48 CLASS 35. Impellers and field adjustable/replaceable, wear plate shall be high chrome iron. Internal and external surfaces coming into contact with the pumpage shall be protected by a fused polymer coating. All exposed fasteners shall be stainless steel. All units up to 15 HP shall be furnished with 150 lb. (10 kg/cm²) flat face flange and NPT companion flange. Units 30 HP and above shall be furnished with 300 lb. (20 kg/cm²) flat face flange and NPT companion flange. Impellers shall be of the multi-vane, enclosed solids handling design, equipped with back pump out vanes and shall be slip fit to the shaft and key driven. The unit(s) shall include built in cathodic protection.

3. MECHANICAL SEAL -

All units shall be furnished with a dual inside mechanical shaft seal located completely out of the pumpage, running in a separate oil filled chamber and further protected by an exclusionary oil seal located between the bottom seal faces and the fluid being pumped. The oil chamber shall be fitted with a device that shall provide positive lubrication of the top mechanical seal, (down to one third of the standard oil level). The device shall not consume any additional electrical power. Mechanical seals shall be rated to preclude the incursion of water up to 42.6 PSI (98.4 Ft.) submergence. Units shall have silicon carbide mechanical seal faces. Mechanical seal hardware shall be stainless steel. Unit(s) shall incorporate seal pressure relief ports. All unit(s) shall be fitted with replaceable shaft sleeves.

4. MOTOR-

The pump motor(s) shall be _____H P., _____kW., _____V., 60 Hz. 3 Phase and shall be NEMA MG-1, Design Type B equivalent. Motor(s) shall be rated at _____full load amps. Motor(s) shall have a 1.15 service factor and shall be rated for 20 starts per hour. Motor(s) shall be air filled, copper wound, class B or F (40 HP) insulated with built in thermal protection for each winding. Motor shaft shall be 420 stainless steel and shall be supported by two high temperature bearings, with a B-10 life rating at best efficiency point of 60,000 hours. The bottom bearing on unit 7.5 HP shall be two row, double shielded, C3, deep groove type ball bearing. Units 15 Hp and above shall have two row, re-greasable, C3, angular contact type ball bearing. The top bearing on all units shall be single row, double shielded, C3, deep groove type ball bearing. Motors shall be D.O.L. or star-delta start (40 HP) and shall be suitable for across the line start or variable speed applications, utilizing a properly sized variable frequency drive.

5. POWER CABLE AND CABLE ENTRANCE -

The pump power cable shall be suitable for submersible pump applications and shall be field replaceable utilizing standard submersible pump cable. The cable entrance shall incorporate built in strain relief and a combination three way mechanical compression sealing with a fatigue reducing boot. The cable entrance assembly shall contain a anti-wicking block to eliminate water incursion into the motor due to capillary wicking should the power cable be accidentally damaged.